

NSW Swimming Pool Register

POOL 'SELF ASSESSMENT' CHECKLIST - INDOOR POOLS



Does your pool meet the safety standards?

Window restrictions for indoor pools

| | | |
|---|---------------------------|--------------------------|
| The windows can only open to a maximum of 100mm | <input type="radio"/> Yes | <input type="radio"/> No |
| OR The windows are totally covered by bars or a mesh screen | <input type="radio"/> Yes | <input type="radio"/> No |
| OR The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor | <input type="radio"/> Yes | <input type="radio"/> No |

Doors that have access to pools

| | | |
|--|---------------------------|--------------------------|
| There is a latch on the door at least 1500mm above floor level | <input type="radio"/> Yes | <input type="radio"/> No |
| Doors open away from the pool area and are self-latching | <input type="radio"/> Yes | <input type="radio"/> No |
| There are no pet doors or openings greater than 100mm | <input type="radio"/> Yes | <input type="radio"/> No |

Wall restrictions for indoor pools

| | | |
|---|---------------------------|--------------------------|
| There are no wall openings greater than 100mm | <input type="radio"/> Yes | <input type="radio"/> No |
|---|---------------------------|--------------------------|

Around the pool

| | | |
|---|---------------------------|--------------------------|
| There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres. | <input type="radio"/> Yes | <input type="radio"/> No |
|---|---------------------------|--------------------------|

If you have answered '**No**' to any of the questions above, please contact your local council for further information.

bepoolsafe.com.au / swimmingpoolregister.nsw.gov.au

