



NOTE 1: 1009 REFERENCES DRAWING SD_820_10 (ULTRASONIC LEVEL SENSOR) 1026 REFERENCES DRAWING SD_820A_10 (PRESSURE LEVEL SENSOR). REFER TO APPROPRIATE DRAWING DEPENDING ON SITE.

NOTE 2: SPEED REF FOR NON MODBUS VSD'S. NOT TO BE USED EXTERNALLY OR ON NEW BUILDS (GREENFIELD) ADDITIONAL ANALOG OUTPUT CARD WOULD BE REQUIRED

ISSUE	AMENDMENT DETAILS	Drawn	Checked	Approved	Date
00	ORIGINAL ISSUE			D.F	3.8.12
01	AMENDED ISSUE RELEASED FOR PUBLICATION	E.K	P.B	D.F	13.08.13
02	AMENDED TERMINAL NAMES & TITLE BLOCK	E.K	P.B	D.F	27.04.15
03	ADDED NOTE FOR SPEED REF	C.N	P.B	J.G	14.08.18
04	UPDATED FLOW METER WIRE NUMBERS	P.B	D.R	J.G	13.08.20

ELECTRICAL UNIT
 COUNCIL OFFICES
 ALTONA ROAD,
 CUDGEN NSW 2487.

PHONE 02 66740342
 FAX 02 66741069
 WEBSITE www.tweed.nsw.gov.au

DESIGNED:		PROJECT:	SEWAGE PUMP STATIONS ELECTRICAL STANDARD DRAWINGS	DRAWING NUMBER:	SD-820/08
DRAWN:		PLAN TITLE:	SCADAPack 357e RTU ANALOG I/O SCHEMATIC	SHEET	08 OF 19
APPROVED:				REV	04
SCALE	NTS			DATE	13/08/2020
ACAD FILE No.:					