


- NOTES:**
- REFER TO THE PIPEWORK SCHEDULE IN DWG S.D.220-06 FOR PIPEWORK DETAILS SHOWN THUS (1)
  - ENSURE THAT ALL VALVES WITHIN THE VALVE PIT ARE ACCESSIBLE FROM ABOVE WITHOUT THE NEED TO REMOVE THE BEAM.
  - THE FLOWMETER IS TO BE LOCATED A MINIMUM DISTANCE OF 10 x DIAMETER OF THE MAIN FROM ANY UPSTREAM FITTING & A MINIMUM DISTANCE OF 5 x DIAMETER OF THE MAIN FROM ANY DOWNSTREAM FITTING & INSTALLED AS PER MANUFACTURER'S RECOMMENDATIONS.
  - THE ISOLATION VALVE IS TO BE LOCATED AT LEAST 5 x THE DIAMETER OF THE MAIN DOWNSTREAM OF THE FLOWMETER.



F	ACCESS COVERS TYPE AMENDED	J.M.M.	06.2021
E	ACCESS COVERS AMENDED	S.K.J	03.2019
D	REMOVED ACCESS LADDER AND AMENDED NOTES	S.K.J	03.2019
C	DROP PIPE ADDED TO INLET	A.K.R.	09.2015
B	PIPEWORK UPGRADED & NOTES AMENDED	G.P.C.	06.2015
A	ORIGINAL ISSUE (NEW SHEET - PREVIOUSLY PART OF S.D.220/03. FLOWMETER & NOTES ADDED)	G.P.C.	08.2014
ISSUE	AMENDMENT DETAILS	INITIALS	DATE



**DESIGN UNIT**  
 COUNCIL OFFICES  
 TUMBULGUM ROAD,  
 MURWILLUMBAH,  
 NEW SOUTH WALES 2484  
 PHONE 02 6670 2400  
 FAX 02 6672 7513  
 WEBSITE www.tweed.nsw.gov.au

DESIGN ENGINEER	<i>Adm</i>	DATE 14.09.15
DESIGN MANAGER	<i>Phy</i>	DATE 14.09.15
DRAWN	ENGINEERING & OPERATIONS DESIGN UNIT	
SCALE	1:40 (A3)	

PROJECT:	<b>SEWERAGE WORKS STANDARDS</b>	DRAWING NUMBER:	<b>S.D.220-04</b>
PLAN TITLE:	<b>2.0m DIAMETER PUMP STATION (SHEET 4 OF 6 SHEETS) SECTIONAL PLAN &amp; SECTION 'A'</b>		<b>JUNE 2021</b>
ACAD FILE No: G:\_AAA TSC STANDARD DRAWINGS\200 SEWERAGE WORKS\S.D.220-04 (June - 21 Rev F)			

