



## <u>NOTES</u>

- 1. REFER DRG NO. S.D.221-01 FOR GENERAL AND MATERIAL NOTES.
- 2. REFER DRG NO. S.D.221-09 FOR VALVE CHAMBER ACCESS COVER AND GRATE
- 3. FOR COVERS WITH A TOTAL LIFTING WEIGHT LESS THAN 16kg, A SINGLE KEYWAY BOX SHALL BE PROVIDED CENTRALLY (REFER THREE AND ALTERNATIVE MULTI-COVER PLANS), UNLESS REQUESTED OTHERWISE BY THE PRINCIPAL. FOR COVERS WITH A TOTAL LIFTING WEIGHT GREATER THAN 16kg, DUAL KEYWAY BOXES AND AN ETCHED WARNING PLATE SHALL BE PROVIDED (REFER SINGLE AND DUAL COVER PLANS).
- 4. BULLET HINGES SHALL BE ORIENTATED IN OPPOSITE DIRECTIONS TO RESTRICT THE REMOVAL OF THE COVER.





ALTERNATIVE MULTI-COVER PLAN

SHEET No. 8

В	GENERAL REVISION	CAH	07.22
Α	ORIGINAL ISSUE	CAH	06.22
ISSUE	AMENDMENT DETAILS	INITIALS	DATE

TWEED SHIRE COUNCIL

DESIGN UNIT
COUNCIL OFFICES
TUMBULGUM ROAD,
MURVILLUMBAH,
NEW SOUTH WALES 2484

PHONE 02 6670 2400
EMAIL tsc@tweed.nsw.gov.au

DESIGN ENGINEER

After DATE JUNE 2022

W & WW MANAGER

DATE JUNE 2022

DATE JUNE 2022

DRAWN

INFRASTRUCTURE DELIVERY UNIT - DESIGN

SCALE

NOT TO SCALE

SEWERAGE WORKS STANDARDS

S.D.221-08

**JUNE 2022** 

VALVE CHAMBER ACCESS COVERS
GENERAL ARRANGEMENT PLANS

ACAD FILE NO: G1\_AAA TSC STANDARD DRAWINGS/200 SEWERAGE WORKSIDRAFTS-DONT USEIS D.221-08 (July-22 Rev B).dwg