



TYPICAL PLAN



SERVICE MARKERS

NOTES:

1. WATER SERVICE CONDUITS TO BE UPVC CLASS 12, OR PE 80 TYPE B CLASS PN12.5. CONDUIT TO HAVE 600mm MIN COVER UNDER ROAD PAVEMENT, AND TO BE 100mm MIN DIA FOR RESIDENTIAL SERVICES, & 150mm MIN DIA FOR COMMERCIAL & INDUSTRIAL SERVICES. CONDUITS TO EXTEND BELOW FOOTPATHS
2. WATER SERVICE PIPE TO BE 32mm OD PE 80 TYPE B CLASS PN16 TO AS4130
3. ALL WATER SERVICE PIPEWORK & ASSOCIATED FITTINGS SHALL BE JOINTED IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS
4. BRASS 'W' MARKER TO BE SET IN KERB TO MARK LINE OF CONDUIT CROSSING THE ROAD SS METER BOX MARKER TO BE DRILLED AND PINNED TO MARK METER BOX POSITION
5. CHANGE OF DIRECTION IN SERVICE PIPES TO BE ACHIEVED USING SMOOTH LONG RADIUS TRANSITION CURVES. MINIMUM PIPE BENDING RADII TO BE OBSERVED
6. ALL PIPE FITTINGS TO COMPLY WITH TWEED SHIRE COUNCIL DEVELOPMENT DESIGN SPECIFICATION D-11 WATER SUPPLY.
7. INSTALLATION OF WATER SERVICES TO BE COMPLETED AFTER POWER & TELSTRA. WHERE DISTANCE BETWEEN WATER SERVICE AND ELECTRICAL BOX WOULD BE LESS THAN 500mm, WATER SERVICE POSITION TO BE MOVED TO OPPOSITE SIDE OF LOT
8. SERVICES LARGER THAN 40mm HAVE METERS INSTALLED ABOVE GROUND, REFER S.D.322
9. WATER SERVICE TO BE LOCATED ON OPPOSITE SIDE OF LOT TO ELECTRICAL SUPPLY
10. REFER TSC SD 320 - 327 FOR PROPERTY SERVICE DETAILS
11. WHERE WATER MAIN IS LOCATED WITHIN ROAD PAVEMENT OR ROAD SHOULDER, THE ENTIRE SERVICE SHALL BE INSTALLED IN THE SAME INTERNAL DIAMETER COPPER PIPE IN PLACE OF PE PIPE.



TYPICAL SECTION

ISSUE	AMENDMENT DETAILS	INITIALS	DATE
C	NOTES AMENDED & PLAN FORM UPGRADED	G.P.C.	06.2015
B	NOTE 11 ADDED	G.P.C.	05.2009
A	ORIGINAL ISSUE	G.P.C.	05.2006




DESIGN UNIT
 COUNCIL OFFICES
 TUMBULGUM ROAD,
 MURWILLUMBAH,
 NEW SOUTH WALES 2484
 PHONE 02 6670 2400
 FAX 02 6672 7513
 WEBSITE www.tweed.nsw.gov.au

DESIGN ENGINEER	<i>Ahu</i>	DATE 11.05.15
DESIGN MANAGER	<i>P. May</i>	DATE 22.05.15
DRAWN	ENGINEERING & OPERATIONS DESIGN UNIT	
SCALE	NOT TO SCALE	

PROJECT:	WATER SUPPLY STANDARDS
PLAN TITLE:	PROPERTY SERVICE LAYOUT DN 50 OR SMALLER SERVICES

DRAWING NUMBER:	S.D. 302
	JUNE 2015



ACAD FILE No: G:_AAA TSC STANDARD DRAWINGS\300 WATER SUPPLY\S.D.302 (June-15 Rev C).dwg